



North Huntingdon Township  
Fire Official's Report  
January 2022

Submitted by North Huntingdon Township  
Planning and Zoning Department

\*Fire Code Officials  
Josh Andrykovitch/Thomas McGuire

# January 2022 Fire Inspection Report

Business Name	Date Inspected	Occupancy Classification	Fire Extinguishers Current	Sprinkler System Current	Ansil System Current	Emergency Lights/Illuminated Exit Signs	Emergency Egress Clear/Blocked	* Deficiencies *	
								Yes	No
ExOne	12/2/21	Factory	Yes	Yes	Yes	Clear	Clear	Emergency exit sign not illuminated	X
Kenny Ross Tough Trucks	12/6/21	Business	Yes	N/A	N/A	Clear	Clear	Temporary occupancy issued until the rest of the materials arrive to finish the project	X
Meineke	12/9/21	Storage	Yes	N/A	N/A	Blocked	Blocked	Emergency lighting not working Emergency exits blocked with materials	X
Pep Boys	12/9/21	Business/Storage	Yes	N/A	N/A	Blocked	Blocked	Emergency exit blocked with materials	X
Evolve Esthetics	12/17/21	Business	Yes	N/A	N/A	Clear	Clear	Commercial occupancy issued	
Savage Detailing	12/23/21	Business	Yes	N/A	N/A	Clear	Clear	Commercial occupancy issued	
The Lone Oni	12/28/21	Business	Yes	N/A	N/A	Clear	Clear	Commercial occupancy issued	
Stevenson Flooring	1/7/22	Mercantile	Yes	N/A	N/A	Clear	Clear	Emergency exit signs not illuminated	X
Fat Pocket Billiards	1/7/22	Assembly	N/A	N/A	N/A	N/A	N/A	No occupancy permit was issued for this business. Owner to submit paperwork for occupancy/fire inspection.	X
AccuServ Pharmacy	1/14/22	Business	Yes	N/A	N/A	Clear	Clear	Emergency lighting not working	X
Great Clips	1/14/22	Business	Yes	N/A	N/A	Clear	Clear	No deficiencies found	
Don's Appliance	1/14/22	Mercantile	Yes	N/A	N/A	Clear	Clear	Furniture placed within the turning radius of the handicap accessible bathroom.	X