



North Huntingdon Township
Fire Official's Report
March 2022

Submitted by North Huntingdon Township
Planning and Zoning Department

*Fire Code Officials
Josh Andrykovitch/Thomas McGuire

March 2022 Fire Inspection Report

Business Name	Date Inspected	Occupancy Classification	Fire Extinguishers Current	Sprinkler System Current	Ansil System Current	Emergency Lights/Illuminated Exit Signs	Emergency Egress Clear/Blocked	* Deficiencies *	
								Yes	No
Avis	2/9/22	Business	Yes	N/A	N/A	Yes	Clear	* Removal of combustibles from around furnace	X
Enterprise Rent-A-Car	2/9/22	Business	No	N/A	N/A	Yes	Clear	* Emergency lighting not working Fire extinguishers need a current inspection tag	X
Chrissy & Co. Salon	2/9/22	Business	Yes	N/A	N/A	Yes	Clear	* No deficiencies found	
Domino's	2/9/22	Business	Yes	N/A	Yes	Yes	Clear	* Rear exit sign not working	X
Kellar Williams	2/9/22	Business	No	N/A	N/A	Yes	Clear	* Fire extinguisher needs a current inspection tag	X
Franklin Lager & Ales	2/10/22	Assembly	Yes	N/A	N/A	Yes	Clear	* No deficiencies found	
Coldwell Banker	2/16/22	Business	Yes	N/A	N/A	Yes	Clear	* No deficiencies found	
Crumb! Cookie	2/16/22	Mercantile	Yes	N/A	N/A	Yes	Clear	* Emergency lighting not working properly	X
Angel Autobody	2/22/22	Business	Yes	N/A	N/A	Yes	Clear	* Fire extinguisher and emergency lighting needed for occupancy	X
Two Ladies and a Gentleman Catering	3/2/22	Business	Yes	N/A	Yes	Yes	Clear	* No deficiencies found	
Subway - Norwin Hills	3/10/22	Assembly	Yes	N/A	N/A	Yes	Clear	* No deficiencies found	
Sherwin Williams	3/10/22	Mercantile	Yes	N/A	N/A	Yes	Clear	* Exit sign not illuminated	X