



North Huntingdon Township
Fire Official's Report
April 2022

Submitted by North Huntingdon Township
Planning and Zoning Department

*Fire Code Officials
Josh Andrykovitch/Thomas McGuire

April 2022 Fire Inspection Report

Business Name	Date Inspected	Occupancy Classification	Fire Extinguishers Current	Sprinkler System Current	Ansil System Current	Emergency Lights/Illuminated Exit Signs	Emergency Egress Clear/Blocked	* Deficiencies *		Deficiencies Corrected	
								Yes	No	Yes	No
Sherwin Williams	3/10/22	Mercantile	Yes	N/A	N/A	Yes	Clear	* Exit sign not illuminated		X	
Salsa Sam's Eatery	3/25/22	Assembly	Yes	N/A	N/A	Yes	Clear	* Commercial occupancy issued			
Northern Sky Dental	4/1/22	Business	Yes	N/A	N/A	Yes	Clear	* Commercial occupancy issued			
Boston Mini Mart	4/1/22	Mercantile	Yes	N/A	N/A	Yes	Clear	* No deficiencies found			
Taco Bell	4/4/22	Assembly	Yes	N/A	N/A	Yes	Clear	* No deficiencies found			
Speed Foodmart	4/11/22	Mercantile	Yes	N/A	N/A	Yes	Blocked	* Emergency exit door may not be locked during hours of operation		X	
Stoney's Building Supply	4/11/22	Mercantile	Yes	N/A	N/A	Yes	Clear	* Fire extinguishers tag is expired			X
Stoney's Kitchen & Bath	4/11/22	Mercantile	Yes	N/A	N/A	Yes	Clear	* No deficiencies found			
GDC	4/12/22	Mercantile	Yes	N/A	N/A	Yes	Clear	* No deficiencies found			
Black Mandala Tattoo	4/12/22	Business	Yes	N/A	N/A	Yes	Clear	* Emergency lighting not operating properly			X
PT Group	4/12/22	Business	Yes	N/A	N/A	Yes	Clear	* No deficiencies found			
Steel City Simulators	4/12/22	Assembly	Yes	N/A	N/A	Yes	Clear	* Exit sign not operating properly * Emergency lighting not operating properly * Fire extinguisher damaged			X