



North Huntingdon Township  
Fire Official's Report  
May 2022

Submitted by North Huntingdon Township  
Planning and Zoning Department

\*Fire Code Officials  
Josh Andrykovitch/Thomas McGuire

# May 2022 Fire Inspection Report

Business Name	Date Inspected	Occupancy Classification	Fire Extinguishers Current	Sprinkler System Current	Ansl System Current	Emergency Lights/Illuminated	Exit Signs	Emergency Egress Clear/Blocked	* Deficiencies *	
									Yes	No
Speed-D Foodmart	4/11/22	Mercantile	Yes	N/A	N/A	Yes	Blocked	Blocked	X	* Emergency exit door may not be locked during hours of operation
Stoney's Building Supply	4/11/22	Mercantile	Yes	N/A	N/A	Yes	Clear	Clear	X	* Fire extinguishers tag is expired
Black Mandala Tattoo	4/12/22	Business	Yes	N/A	N/A	Yes	Clear	Clear	X	* Emergency lighting not operating properly
Steel City Simulators	4/12/22	Assembly	Yes	N/A	N/A	Yes	Clear	Clear	X	* Exit sign not operating properly * Emergency lighting not operating properly * Fire extinguisher damaged
Sheetz (Rhonda Ct.)	5/10/22	Mercantile	Yes	N/A	Yes	Yes	Clear	Clear	X	* Remove materials from mechanical room
Sheetz (N. Thompson Ln.)	5/10/22	Mercantile	Yes	N/A	Yes	Yes	Clear	Clear	X	* Remove materials from mechanical room
Sheetz (Carpenter Ln.)	5/10/22	Mercantile	Yes	N/A	Yes	Yes	Clear	Clear		* No deficiencies found
BP (Arona Rd.)	5/10/22	Mercantile	Yes	N/A	N/A	Yes	Clear	Clear		* No deficiencies found
Busy Beaver	5/10/22	Mercantile	Yes	Yes	N/A	Yes	Clear	Clear	X	* Remove materials from mechanical room * Emergency lighting not working
Country Hammer Moonshine	5/12/22	Mercantile	Yes	N/A	N/A	Yes	Clear	Clear		* No deficiencies found