

**TOWNSHIP OF NORTH HUNTINGDON
WESTMORELAND COUNTY, PENNSYLVANIA
DEPARTMENT OF PUBLIC WORKS**

**RICHARD G. ALBERT, DIRECTOR OF PUBLIC WORKS
TAB N. FYOCK, ASST. DIRECTOR OF PUBLIC WORKS**

2022

VIRGINA AVE:

Part of the township drainage system that was failing and needed replaced in preparation for this year's paving program.

- Saw cut and excavation
- Replaced 200' of 12" pipe
- Replaced 30' of 15" pipe
- Re-constructed 5 inlets
- Resurface all areas

HAYWOOD RD:

Part of the Township drainage system that was failing and needed replaced in preparation for this year's paving program.

- Saw cut and excavation
- Replaced 30' of 15" pipe
- Re-constructed 5 inlets
- Resurfaced all areas

COMSTOCK DR:

Part of the Township drainage system that was failing and need replaced in preparation of this year's paving program.

- Saw cut and excavation
- Installed 400' of 6" under drain behind curb

GARLOW RD:

Part of the Township drainage that was failing causing unsafe conditions.

- Saw cut and excavation
- Replaced 30: of 15" pipe
- Re-Surfaced all areas

INLET REPAIR:

Part of the Township drainage system that was failing causing unsafe conditions.

- Willow Dr: Re-constructed 1 inlet, Re-surface all areas,
- Huntingdon Ave Re-constructed 1 inlet,
- Water St Re-constructed 5 inlets,
- Oakcrest Dr Re-constructed 1 inlet,

NEHRIG HILL RD:

- UNEXPECTED ROAD SLIDE: One lane on the low side of the road dropped 8 to 10 inches. 150' of 6" under drain was installed to re-direct water, a temporary road was constructed so resident is able to safely get to their home.

SIGN DEPARTMENT:

- The Sign Department continues their regular duties of installation of road signs based on legal criteria. They also have the duties of marking the PA One Calles and tracking permitting and inspection of road openings.

STREET SWEEPER UPDATE:

- OUT OF SERVICE.

MOWER:

- The mower is out when able.

EMERGENCY CALL IN:

- 7/11/22 Comstock Dr. Stop Sign
- 7/18/22 Pershing Dr. Stop Sign
- 7/28/22 Camelot Close Streets

If you have any questions concerning this report, please feel free to contact me.

Richard Albert

Richard G. Albert
Director of Public Works