



North Huntingdon Township
Fire Official's Report
August 2022

Submitted by North Huntingdon Township
Planning and Zoning Department

*Fire Code Officials
Josh Andrykovitch/Thomas McGuire

August 2022 Fire Inspection Report

Business Name	Date Inspected	Occupancy Classification	Fire Extinguishers Current	Sprinkler System Current	Ansil System Current	Emergency Lights/Illuminated	Exit Signs	Emergency Egress Clear/Blocked	* Deficiencies *		Deficiencies Corrected	
									Yes	No	Yes	No
Norwin High School Aquatics	7/5/22	Assembly	Yes	Yes	N/A	Yes	Clear	Clear			X	
Shop & Save	7/7/22	Mercantile	Yes	Yes	Yes	Yes	Clear	Clear	* Removal of items from mechanical room		X	
GNC	7/7/22	Mercantile	No	N/A	N/A	Yes	Clear	Clear	* Fire extinguisher tags are expired		X	
Speedy Furniture	7/7/22	Mercantile	Yes	N/A	N/A	Yes	Clear	Clear	* Removal of items from mechanical room		X	
Rite Aid - Norwin Hills	7/29/22	Mercantile	Yes	N/A	N/A	Yes	Clear	Clear	* Outlet covers missing on the exterior of the building		X	
Nelson Loguasto Cigar Company	8/8/22	Business	Yes	Yes	N/A	Yes	Clear	Clear	* Commercial occupancy issued			
McDonald's - Norwin Town Square	8/8/22	Assembly	Yes	N/A	Yes	Yes	Clear	Clear	* No deficiencies found			
United Career Institute	8/11/22	Assembly	Yes	Yes	N/A	Yes	Clear	Clear	* No deficiencies found			
Xfinity	8/11/22	Mercantile	Yes	Yes	N/A	Yes	Clear	Clear	* No deficiencies found			
Five Guys	8/11/22	Assembly	Yes	Yes	Yes	Yes	Clear	Clear	* Ansil fire extinguisher need an inspection tag			X
Barnes Lake Animal Hospital	8/12/22	Business	Yes	N/A	N/A	Yes	Clear	Clear	* Commercial occupancy issued			